



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI/CAN Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on February 7, 2020.

Balmoral Tanks Ltd.
Balmoral Park, Loirston
Aberdeen AB12 3GY
United Kingdom
44 122 489 5000

Facility: South Yorkshire, United Kingdom

Protective (Barrier) Materials

Trade Designation	Water Contact	Water Contact	Water Contact
	Size Restriction	Temp	Material
Storage Tanks/Reservoirs [1] [G]			
Balmoral Tanks- Efusion@[2]	>= 3000 gal.	CLD 23	MLTPL
Balmoral Tanks- Efusion@ 1500[2]	>= 3000 gal.	CLD 23	MLTPL

[1] Only products bearing the NSF Mark on the product, product packaging, and/or documentation shipped with the product are Certified.

[2] Certification includes bolted steel tanks with the following: epoxy coated carbon steel panels and appurtenances, stainless steel appurtenances, tank sealant, and rubber gaskets. Floor may be epoxy coated carbon steel or concrete coated with NSF Certified coating. Certification does not include the concrete as it is applied in the field by the end user and is not supplied by Balmoral Tanks. All NSF Certified coatings must be Listed for tanks at least 3000 gallons and greater and application must occur according to Certified specifications.

[G] Product is Certified to NSF/ANSI 372 and conforms with the lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.